

## Building Product Information Sheet

Product name:

Danfoss Lock shield valve

Product line (the product line from which the product is customised):

Radiator valves

Product description and its intended use (measurements, materials, usage):

Chrome-plated Designer Series valve suitable for use with water heated radiators and towel rails.

RA-NCX and RLV-CX is a series of chrome plated radiator valves and lock shield valves, especially designed for use with design radiators. A new tailpiece with an O-ring seal ensures an aesthetically appealing connection to the radiator without the need for sealing tape or compound.

Product identifier (if applicable):

DANLSANG/DANLSST/DANTHANG

Please of manufacturer:  Aotearoa New Zealand  Overseas

Legal and trading name of the manufacturer(s):

Danfoss

Legal and trading name of the manufacturer(s):

Central Heating New Zealand Ltd

Address for service:

STREET NAME 52 Pilkington Way

SUBURB Wigram

CITY, COUNTRY Christchurch, New Zealand

POSTCODE 8042

Website:

<https://www.centralheating.co.nz/>

Email Address:

[info@centralheating.co.nz](mailto:info@centralheating.co.nz)

Phone No. (if applicable):

03 357 1233

NZBN (if applicable):

9429036621231



Relevant Building Code clauses:

Clause B2 DURABILITY:

Performance B2.3.1 (b)

Clause F2 HAZARDOUS BUILDING MATERIALS:

Performance F2.3.1.

Clause G10 PIPED SERVICES:

Performance G10.3.1 (a).

Statement on how the building product is expected to contribute to compliance:

Clause B2 DURABILITY:

Performance B2.3.1 (b) 15 years. radiator valves are moderately easy to access and replace if installed in accordance with the instructions and product requirements.

Clause F2 HAZARDOUS BUILDING MATERIALS:

Performance F2.3.1. Radiator valves meet this requirement and do not present a health hazard to people.

Clause G10 PIPED SERVICES:

Performance G10.3.1 (a). radiator and associated valves are supplied by a non-potable piping system, which contributes to meeting this requirement when used in heating systems.

- *options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)*
- *standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured.*
- *physical properties of the building product*
- *how the building product is intended to be used.*

**Limitations on the use of the building product:**

Please refer to the radiator valve technical [datasheet](#) and product specification supporting information provided on the Central Heating NZ website.

The hot water heating system must not be connected to the potable water supply system.

Radiator valves are not suitable for potable water supply.

**Design requirements that would support the use of the building product:**

The heating system design, including the layout of the pipe, must be carried out by a suitably qualified designer.

Please refer to the radiator valve technical [datasheet](#) and product specification supporting information provided on the Central Heating NZ website.

Design must consider the requirement of building code clause H1 for pipework and heating design.

**Installation requirements:**

Please refer to the radiator valve technical [datasheet](#) and product specification [supporting information](#) provided on the Central Heating NZ website.

All positions and heights above finished floor level of the radiators are to be confirmed on site before installation. Co-ordination between trades is essential. Ensure the main contractor has been engaged when confirming radiator locations to ensure they do not interfere with fixings or furniture.

RA-NCX are supplied with a protective cap and adjusting screw, which can be used for manual regulation during the construction phase. The protective cap must not be used as a manual shut off device.

The pressure pin of the gland seal is made of chromium steel and works in a lifetime lubricated O-ring. The complete gland seal can be replaced without draining down the system.

A detailed as-built plan and site photos shall be provided upon the conclusion of installation showing location of all concealed pipework supplying the radiator(s)

Maintenance requirements:

Visual inspection annually.

Is the building product/building product line subject to warning or ban under section 26:

Yes  No

If yes, description of the warning or ban under section 26:

Date:

3 0 0 8 2 3