

CLASS 1

Building Product Information Sheet

Product name:

Danfoss Internal Radiator Valve

Product line (the product line from which the product is customised):

Internal Radiator Valves

Product description and its intended use (measurements, materials, usage):

Integrated valves, type RA-N (013G0372) and RAU (013G0373), with built-in presetting are designed for incorporation into valve radiators from different radiator manufacturers.

The two valve types can be recognised by the colour of the presetting ring:

- Red: RA-N
- Yellow: RA-U

Integrated valves can be used in single and two pipe installations with circulating pump Available in White, Black, and Red

not for use with potable water.

Product identifier (if applicable):

DAN013G0372, DAN013G1489, DAN013G1401

Please of manufacturer: Aotearoa New Zealand Overseas

Legal and trading name of the manufacturer(s):

Danfoss

Legal and trading name of the manufacturer(s):

Central Heating New Zealand Ltd

Address for service:

STREET NAME 52 Pilkington Way

SUBURB Wigram

CITY, COUNTRY Christchurch, New Zealand

POSTCODE 8042

Website:

<https://www.centralheating.co.nz/>

Email Address:

info@centralheating.co.nz

Phone No. (if applicable):	03 357 1233
NZBN (if applicable):	9429036621231

Relevant Building Code clauses:

<p>Clause B2 DURABILITY: Performance B2.3.1 (b)</p> <p>Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1.</p> <p>Clause G10 PIPED SERVICES: Performance G10.3.1 (a).</p>

Statement on how the building product is expected to contribute to compliance:

<p>Clause B2 DURABILITY: Performance B2.3.1 (b) 15 years. Valves are moderately easy to access and replace if installed in accordance with the instructions and product requirements.</p> <p>Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Brass valves meet this requirement and do not present a health hazard to people.</p> <p>Clause G10 PIPED SERVICES: Performance G10.3.1 (a). Heating valves are supplied by a non-potable piping system, which contributes to meeting this requirement when used in heating systems.</p>
--

- options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)
- standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured.
- physical properties of the building product
- how the building product is intended to be used.

Limitations on the use of the building product:

Please refer to the Danfoss Internal Radiator Valve [technical information](#) provided on the Central Heating NZ website.

The hot water heating system must not be connected to the potable water supply system.
valve is not suitable for potable water supply.

Design requirements that would support the use of the building product:

The heating system design, including the layout of the pipe, must be carried out by a suitably qualified designer.

Please refer to the valve technical information provided on the Central Heating NZ website.

Design must consider the requirement of building code clause H1 for pipework and heating design.

Installation requirements:

Please refer to the valve technical information and installation [instructions](#) provided on the Central Heating NZ website.

The system installation must be carried out by a licensed and qualified tradesperson, in accordance with the design supplied by the suitably qualified designer.

A detailed as-built plan and site photos shall be provided upon the conclusion of installation showing location of all associated pipework and the radiator (with valve) location on a heating schematic.

Maintenance requirements:

The gland seal of the valve can be replaced while the system is in operation.

Is the building product/building product line subject to warning or ban under section 26:

Yes No

If yes, description of the warning or ban under section 26:

Date:

3 0 0 8 2 3